LISTING SERVICE

LISTING No.   7300-0067:146   Page 1 of 1

CATEGORY: Misc Device/Control Unit Accessories

LISTEE: Siemens Building Technologies Inc., *Fire Safety Div., 8 Fernwood Rd, Florham Park NJ 07932
Contact: Peter Pawchak (973) 593-2662 Fax (973) 593-6652

DESIGN: Models TRI-2, TRI-2D, TRI-2R, TRI-60, TRI-60D, TRI-60R, TRI-B6, TRI-B6D, TRI-B6R, TRI-B6M, TRI-D, TRI-R and TRI-S addressable modules and TRI-CB supervisory module. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name or Cerberus Pyrotronics, model number and UL label.

APPROVAL: Listed as control unit accessories for use with Model XL3 (CSFM Listing No. 7165-0067:104 and 7170-0067:151), Model MXL (CSFM Listing No. 7165-0067:144 and 7170-0067:154) or IXL (CSFM Listing No. 7165-0067:138 and 7170-0067:153) fire alarm control units. The TRI-CB module is designed for use with the TRI-2, TRI-2D and TRI-2R modules when interfaced with the INX module.

Rev. 10-26-2002

Date Issued: **OCTOBER 26, 2002**   *Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, *Senior Deputy*
Program Manager